

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1049

Dated: 06.03.2024

It is certified that an inspection team headed by Er. Biswajit Pritya Saha, AE, RWSS, Khordha

(Name of Officers with designation) from ..... PHED

inspected the ONENESS INTERNATIONAL SCHOOL, At:- BARABHOJIA, N. Arjunpur

(Name & Address of the school) on 14.02.2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no 11.8 (wt) dated 13.02.2024

of State Water Testing Laboratory, RWSS, Odisha (PHED Lab) certified that the

Oneness International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 13.02.2027

Signature with Seal : [Signature]

Name : Block Development Officer

Designation : KHORDHA

Name & Address of the Office/Department : .....

To

Chairman  
ONENESS INTERNATIONAL SCHOOL  
At: Barabhojia, P.O.:Nalipada Arjunpur  
Dist: Khordha, Odisha-752057

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized office/ PHED lab / local bodies

[Signature]  
Chairman  
Oneness International School

[Signature]  
Principal  
Oneness International School

**GOVERNMENT OF ODISHA**  
**OFFICE OF THE JOINT DIRECTOR CUM CHIEF FOOD ANALYST**  
**State Food Testing Laboratory, Convent Square, Near Ram Mandir, Bhubaneswar-1**

No. 2873/JDCFA/SFTL, Bhubaneswar, the 30th 12 2023

To,  
**Mr. Dharendra Kumar Behera**  
**Oneness International School**  
**At. Barabhojia, Po. Nalipada, Arjunpur, Khurda.**

Sub: - Analysis report of Water sample.

Report No.	Nature/Name of sample submitted for analysis	Collected/Sent by	Reference No. & Date of Receipt
1480/23	Borewell Water	Dhirendra Kumar Behera	Dt. of Receipt- 11.12.2023

**ANALYSIS REPORT**

The sample of Water falling under Regulation No. 2.10.9 of Food Safety and Standards (Food Products and Food Additive) Regulations, 2011 received on 11.12.2023 has been caused to be analysed and the findings are as under:-

i) Sample Description: - Borewell Water

ii) Physical Appearance: - Water, Dirt & foreign Matter: -Nil, Infestation: -Nil, Other visible contaminants: -Nil

Sl. No.	Quality characteristics	Name of method of test used	Result	Prescribed standards as per a. As per provisions of the Act, and the rules and regulations made there under b. As per label declaration for proprietary food
1.	Colour	FSSAI	Nil	5 Hazen Units
2.	Odour	Manual	Agreeable	Agreeable
3.	Taste		Agreeable	Agreeable
4.	Turbidity		Nil	1 NTU (Max.)
5.	pH		7.0	6.5-8.5
6.	Nitrates (as NO <sub>3</sub> )		Nil	Not more than 45 mg/lit.
7.	Nitrites (as NO <sub>2</sub> )		Nil	Not more than 0.02 mg/lit.
8.	Iron (as Fe)		Nil	Not more than 0.3 mg/lit.
9.	Chloride (as Cl)		26.0 mg/lit	Not more than 250 mg/lit.
10.	Residual chlorine		Nil	Not more than 0.2 mg/lit.
11.	Sulphate (as SO <sub>4</sub> )		Nil	Not more than 200 mg/lit.
12.	Total Alkalinity (as HCO <sub>3</sub> )		104.0 mg/lit	Not more than 600 mg/lit.
13.	Total Hardness (as CaCO <sub>3</sub> )		56.0 mg/lit	Not more than 600 mg/lit.
14.	Total Dissolved Solids		90.38 mg/lit	Not more than 500 mg/lit.
15.	MPN of coliform group of organisms per 100ml		Absent	Absent
16.	Test for E.Coli		Negative	Negative

Remarks: - The sample of Water is conforms to the prescribed standard under FSSAct, 2006 based on the tests performed.

Dated: - **Chairman**  
**Oneness International School**  
 State Food Testing Laboratory  
 Bhubaneswar-1  
**Chairman**  
**Oneness International School**

**Principal**  
**Oneness International School**

81  
 29/12/23  
**Food Analyst**  
**GOVT. OF ODISHA**  
**Food Analyst**  
**Govt. of Odisha**